



SECTION ON & DRIVEWAY

DETAIL OF LIP

1. Panel Width Shall Not Exceed 10' Without A Centerline Contraction Joint.
2. Driveway To Be One Course Concrete Pavement. (See Special Provisions For Class Of Concrete)
3. Gutter To Be Paved Integral With Driveway Pavement.
4. 6" Thick For Residential, 8" Thick For Commercial Drive And Alleys.

I hereby certify that this plan, specification or report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of Minnesota.

DANIEL A. HAAS  
Date \_\_\_\_\_ Lic. No. \_\_\_\_\_

APPROVED \_\_\_\_\_  
CITY ENGINEER

CITY OF ST. PAUL  
DEPARTMENT OF PUBLIC WORKS  
CONCRETE DRIVEWAY  
TYPE 1

Date of Revision  
JULY 2002

Standard Plate No.  
1200C